

Certificate of Compliance

Certificate Number:

UL-US-2424516-0

Report Reference:

E540176-20240621

Issue Date:

2025-11-28

Issued to:

**Zhejiang Chatnow New Material Technology Co Ltd
Floor No. 1, 3 & 4, Building 12, No.9 Huajin Road,
ZhouWangMiao Town, Haining, Jiaxing, Zhejiang, 314407, CN**

This certificate confirms that representative samples of:

**ZOYR - Reaction to Fire and Fire Resistance of Cables Evaluated
in accordance with International Standards**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

EN 50200:2015 PH30 PH60 PH90 PH120

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2424516-0
Report reference E540176-20240621
Date 2025-11-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
300/300 V , 2 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor	Fire Cables Evaluated International Standards
300/300 V , 3 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor	Fire Cables Evaluated International Standards
300/300 V , 4 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor	Fire Cables Evaluated International Standards



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

